

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-1373:114 Page 1 of 1

CATEGORY: Control Unit (Household)

LISTEE: First Alert Professional, 165 Eileen Way, Syosset NY 11791
Contact: David Kalmus (516) 921-6704

DESIGN: Model FA1600CA combination household fire and burglary alarm control unit. Refer to listee's data sheet for additional detailed product description and operational considerations. Minimum system components:

FA1600CA	Control Unit
1451-24, N8167	Transformer
FA250KP, FA550KP	Keypad

RATING: Primary 120 VAC, 18 VAC Secondary, 12 VDC Battery Standby

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a combination household fire and burglary alarm control unit for use with separately listed compatible initiating and indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition. Refer to manufacturer's Installation Manual for details.

- NOTE:
1. **Fire Alarm Verification Feature** (delay of fire alarm) is NOT approved for use in California.
 2. Burglary and other non-fire functions were not examined.

03-19-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 15, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager